



valid until: March 6, 2031

Fraunhofer

TESTED[®] DEVICE

EAE Lighting
BLOOM IP65 60x60
Report No. EA 2602-1723

Single product Particle Emission in Cleanroom (atmospheric)

Qualification Certificate

This is to certify that the product mentioned above, provided by

EAE Lighting
Dilovasi, Turkey

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number EA 2602-1723.

The BLOOM V3 IP65, Recessed Mounted 60x60 cm 36 W LED Luminaire (color: white) was assessed in compliance with ISO 14644-14. When operated under the specified test conditions (room temperature: 22 °C ± 0.5 °C; relative humidity: 45 % ± 5 %), it is suitable for use in cleanrooms fulfilling the specifications of the following Air Cleanliness Class according to ISO 14644-1:

Test parameter(s)	Air Cleanliness Class
Structure-borne noise = approx. 50Hz	1
Overall result	

It should be noted that cleanrooms of Class 1 to 5 according to ISO 14644-1 have a higher filter occupancy, which may restrict the use of panel lighting systems. Cleanrooms with a horizontal displacement flow form an exception to this. The test result may be affected by the surrounding ceiling system.

Please note: Transport damages, incorrect installation, aging behavior, corrosion etc. can influence the test result.

EA 2602-1723 Stuttgart, March 6, 2026
Report No. first document Place, date of first document issued

-- --
Report No. current document Place, current date

on behalf of 
Dr.-Ing. Frank Bürger, head of business unit Testing and Certification

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

The norms stated generally refer to the version valid at the time of the tests.



valid until: March 6, 2031

Fraunhofer

TESTED[®] DEVICE

EAE Lighting
BLOOM IP65 60x60
Report No. EA 2602-1723

Single product Hygienic Design

Qualification Certificate

This is to certify that the product mentioned above, provided by

EAE Lighting
Dilovasi, Turkey

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number EA 2602-1723.

The BLOOM V3 IP65, Recessed Mounted 60x60 cm 36 W LED Luminaire (color: white) is principally suitable for use in hygienic areas up to the following GMP Class according to EU GMP Annex 1:

Suitability
up to GMP Class D

However, this only applies to the tested system in a resting state and requires an overall assessment of the manufacturing environment after installation.

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

The norms stated generally refer to the version valid at the time of the tests.

EA 2602-1723 Stuttgart, March 6, 2026
Report No. first document Place, date of first document issued

-- --
Report No. current document Place, current date

on behalf of 
Dr.-Ing. Frank Bürger, head of business unit Testing and Certification